



APARAT	WYKONANIE	VISTOP-32/4P	R-323-20 D-01/6A-gF	WN-723	R-323-20 D-02/20A-gF	P312-B16-30-AC TB-2/1	P312-B16-30-AC TB-2/2	P312-B16-30-AC TB-2/3	P312-B16-30-AC TB-2/4	P312-B16-30-AC TB-2/5	P312-B16-30-A TB-2/6
OZNACZENIE OBOWODU	• E •	• E •	-	-	-	TB-2/1	TB-2/2	TB-2/3	TB-2/4	TB-2/5	TB-2/6
MOC OBOWODU						1,40 kW	1,40 kW	1,50 kW	1,50 kW	1,50 kW	0,90 kW
TYP PRZEWODU	LY-2x0,5mm ²	LY-2x0,5mm ²			DY1,5mm ²	YDY-2x0,3x2,5mm ²	YDY-2x0,3x2,5mm ²	YDY-2x0,3x2,5mm ²	YDY-2x0,3x2,5mm ²	YDY-2x0,3x2,5mm ²	YDY-2x0,3x2,5mm ²
ODBIORNIK						7 SZT	7 SZT	1 SZT	1 SZT	1 SZT	3 SZT
PRĄD In [A]											
SPADEK NAPIĘCIA ΔU%						0,17 %					
DRUG. PRZEWODU [m]						L=40m					