


OBUDOWA: ATLANTIC INOX
IP-66

nr ref: 035206 - prod: LEGRAND



APARAT	WYKONANIE	VISTOP-32/4P	S303-B6	WN-723	S301-B10	ZEGAR STERUJ. nr ref: 004767	S301-B6	SM400-230-Z2	FR-302/25	S301-B6	SM400-230-Z2
OZNACZENIE OBWODU	• E •	TG-TB02-Z1	-	-	STEROWNICZY	STEROWNICZY	TB-OZ1	TB-OZ1	TB-OZ1	TB-OZ2	TB-OZ2
MOC OBWODU		Pf=2,71 kW Pg=2,71 kW	-	-	-	-	0,16 kW	-	-	0,16 kW	-
TYP PRZEWODU	LY-4x0,6mm ²	5xL1,0mm ² / RVS-37	DY1, 5mm ²	-	1,5mm ² -Cu/250V	1,5mm ² -Cu/250V	1,5mm ² -Cu/250V	YDY-2x3x1,5mm ²	-	1,5mm ² -Cu/250V	YDY-2x3x1,5mm ²
ODBIORNIK		T-G									
PRĄD In [A]		4,3 A									
SPADEK NAPIĘCIA ΔU%		0,03 %									
DRUG. PRZEWODU [m]		5 m									

SCHEMAT IDEOWY.
TABLICA ELEKTRYCZNA TB-OZ.
ZASILANIE, ODPŁYWY.
RYS NR E-10 ark nr 13